

Certificate of Compliance

Certificate Number **20090401- EX15200**
Report Reference **EX15200, 2007 March 09**
Issue Date **2009 April 01**

Page 1 of 1



Issued to: **AL JAZEERA STEEL PRODUCTS CO SAOG**

Po Box 40, Sohar Industrial Estate
Sultanate Of Oman, 327 Oman.

*This is to certify that
representative samples of*

Metallic Sprinkler Pipe

Schedule 40, Grade A, steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6 and 8 in. sizes.


Schedule 40, Grade B, steel pipe in the 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6 and 8 in. sizes.

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: UL 852 - The Standard for Metallic Sprinkler Pipe For Fire Protection - Edition 1, revised July 11, 2005.

Additional Information: All pipes with threaded ends shall conform to ANSI B1.20.1.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Lavanya Govardhanam*

Lavanya Govardhanam, Customer Service Professional

UL India Private Limited

Reviewed by: *Daniel R. Weaver*

Daniel R. Weaver, Project Engineer

Underwriters laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters laboratories Inc. (UL) or any authorized licensee of UL. For question in Singapore you may call +65-62740702.