



Certificate of Compliance

This certificate is issued for the following:

SCHEDULE 40 STEEL SPRINKLER PIPE
SIZES: 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, AND 8 INCH NOMINAL

Prepared For:

Al Jazeera Steel Products Co SOAG
P.O. Box 40, Postal Code 327
Sohar Industrial Estate
Sohar
Sultanate of Oman

FM Approvals Class: 1630. "Steel Pipe for Automatic Fire Sprinkler Systems"

Approval Identification: 3036617 Approval Granted: August 31, 2010

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', written over a horizontal line.

Richard B. Dunne
Group Manager – Hydraulics Group
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

August 31, 2010